FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGERS REPORT

For the month of March 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 994,900 Cubic Ft.

Water sold: 632,300 Cubic Ft.

Water used for Fire & Flushing Line: 69,643 Cubic Ft.

Lag Differential: 29.00%

Average chlorine residual: 0.71 MG/L

II. MAINTENANCE AND REPAIR: March 2017

| Description | Current Month | Last Mo. | Calendar Yr to date |
|-----------------------------|---------------|----------|------------------------|
| | | | |
| METER CHANGES | 3 | 0 | 3 |
| AFTER HOUR CALL OUTS | 5 | 6 | 18 |
| MAIN LINE LEAK REPAIRS | 3 | 8 | 15 |
| USA LOCATES | 19 | 7 | 46 |
| SERVICE/WORK ORDERS | 155 | 136 | 415 |
| CUSTOMER "TURN-ONS" | 5 | 2 | 11 |
| CUSTOMER "TURN-OFFS" | 3 | 1 | 6 |
| LOCK OFF (NON PAYMENT) | 11 | 8 | 27 |
| SERVICE RECONNECT | 9 | 2 | 16 |
| SHUT OFF NOTICES | 56 | 49 | 140 |
| GALLONS CL2 USED | 90 | 85 | 270 |
| WATER QUALITY COMPLAINTS | 0 | 0 | 0 |

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (3) mainline break(s) / repair(s) in the month of March 2017

| Location | Dates | Comments |
|------------------|---------|-----------------------------|
| Encino & Kiwanis | 3/10/17 | 8" Mainline |
| 3817 Main | 3/11/17 | 4" Mainline |
| Creek Bed | 3/17/17 | 8" Transmission Line Repair |

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (5) after hour callout(s) in the month of March 2017

| Location | Dates | Comments |
|------------------|---------|-----------------------------|
| Encino & Kiwanis | 3/10/17 | 8" Mainline Repair |
| 3817 Main | 3/11/17 | 4" Mainline Repair |
| Creek Bed | 3/17/17 | 8" Transmission Line Repair |
| Pine 1 | 3/08/17 | Report of Leak/None Found |
| System Alarm | 3/18/17 | Communication Failure |

V. <u>NEW SERVICES INSTALLED:</u> (0)

| Address | | Lot / Block / Tract | Size |
|---------|--|---------------------|------|
| | | | |

VI. NEW BUSINESS:

■ APPLICATIONS FOR WATER SERVICE -