# FRAZIER PARK PUBLIC UTILITY DISTRICT

## **MANAGERS REPORT**

For the month of July 2023

# Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

#### INFORMATIONAL ITEMS

#### I. WATER REPORT

Water Pumped this month 1,897,400 Cubic Ft.

Water sold: 1,136,530 Cubic Ft.

Water used for Fire & Flushing Line: 132,818 Cubic Ft.

Lag Differential: 33.10%

Average chlorine residual: 0.85 MG/L

#### II. MAINTENANCE AND REPAIR: July 2023

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	2	10	33
AFTER HOUR CALL OUTS	1	3	28
MAIN LINE LEAK REPAIRS	7	3	27
USA LOCATES	17	18	140
SERVICE/WORK ORDERS	701	465	2947
CUSTOMER "TURN-ONS"	1	1	5
CUSTOMER "TURN-OFFS"	1	1	5
LOCK OFF (NON PAYMENT)	2	3	21
SERVICE RECONNECT	2	7	23
SHUT OFF NOTICES	34	37	230
GALLONS CL2 USED	163	145	990
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	1	1	2
SERVICE LINE BREAKS	0	0	2
BOIL WATER NOTICES	450	150	965

#### III. WATER QUALITY COMPLAINTS:

#### IV. ISSUES AND ACTIONS:

There was (7) mainline break(s) / repair(s) in the month of July 2023

1		
Location	Dates	Comments
Summit	7/7/23	4" Steel
4412 Irvon @ Vine	7/7/23	³¼" Steel
4329 Logan Trail	7/11/23	4" Steel
3916 Manita	7/20/23	4" Steel
Los Padres and Glendale	7/24/23	2" Steel
Los Padres @ Escolon	7/26/23	2" Steel
Julin @ Elliot	7/30/23	4" Steel

- Eight (8) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and four (4) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There was (1) after hour callout(s) in the month of July 2023

Location:	Date:	Reason:
Hemmingway	7/29/23	Reported Leak. None Found
		-

### V. <u>NEW SERVICES INSTALLED:</u> (0)

Address	Lot / Block / Tract	Size

#### VI. <u>NEW BUSINESS:</u>

■ APPLICATIONS FOR WATER SERVICE - 0