# FRAZIER PARK PUBLIC UTILITY DISTRICT

## **MANAGERS REPORT**

For the month of April 2023

## Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

### **INFORMATIONAL ITEMS**

## I. WATER REPORT

Water Pumped this month 1,283,700 Cubic Ft.

Water sold: 538,460 Cubic Ft.

Water used for Fire & Flushing Line: 89,859 Cubic Ft.

Lag Differential: 50.05%

Average chlorine residual: 1.56 MG/L

## II. MAINTENANCE AND REPAIR: April 2023

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	8	3	15
AFTER HOUR CALL OUTS	3	6	22
MAIN LINE LEAK REPAIRS	5	3	11
USA LOCATES	38	23	84
SERVICE/WORK ORDERS	464	474	1463
CUSTOMER "TURN-ONS"	1	1	2
CUSTOMER "TURN-OFFS"	2	0	3
LOCK OFF (NON PAYMENT)	3	2	12
SERVICE RECONNECT	4	5	14
SHUT OFF NOTICES	41	38	159
GALLONS CL2 USED	135	149	539
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	1	0	1
SERVICE LINE BREAKS	0	0	1
BOIL WATER NOTICES	150	175	325

#### **III.** WATER QUALITY COMPLAINTS:

#### IV. ISSUES AND ACTIONS:

There was (4) mainline break(s) / repair(s) in the month of April 2023

	(-) / -1 (-	, F
Location	Dates	Comments
809 Buena Vista	4/2/23	2" Mainline
North End & Los Padres	4/12/23	2" Mainline
Smokey & Clay Trails	4/12/23	2" Mainline
Summit	4/18/23	2" Mainline-Replaced 40'
4000 Willow	4/21/23	6" Mainline

- Eight (8) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and four (4) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (3) after hour callout(s) in the month of April 2023

Location:Date:Reason:Summit4/17/23Summit LeakHarrison4/23/23Booster Failure3571 San Fernando4/28/23Emergency Shutoff

## V. NEW SERVICES INSTALLED: (0)

Address	Lot / Block / Tract	Size

#### VI. NEW BUSINESS:

■ APPLICATIONS FOR WATER SERVICE – 0