

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of June 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,247,300 Cubic Ft.

Water sold: 909,167 Cubic Ft.

Water used for Fire & Flushing Line: 87,311 Cubic Ft.

Lag Differential: 20.11%

Average chlorine residual: 0.82 MG/L

II. MAINTENANCE AND REPAIR: June 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	0	3
AFTER HOUR CALL OUTS	9	1	31
MAIN LINE LEAK REPAIRS	3	2	14
USA LOCATES	10	15	76
SERVICE/WORK ORDERS	185	186	1071
CUSTOMER "TURN-ONS"	1	1	11
CUSTOMER "TURN-OFFS"	1	3	10
LOCK OFF (NON PAYMENT)	3	6	30
SERVICE RECONNECT	6	3	29
SHUT OFF NOTICES	24	27	203
GALLONS CL2 USED	120	124	720
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (3) mainline break(s) / repair(s) in the month of June 2019

Location	Dates	Comments
Los Padres & Lomita	6/17/19	6" Mainline
3837 Encino	6/17/19	2" Mainline
2908 Johnson	6/21/19	4" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (9) after hour callout(s) in the month of June 2019

Location	Dates	Comments
Parcel B	6/11/19	Level Adjustment
Parcel B	6/15/19	Level Adjustment
920 Sespe	6/16/19	Emergency Shutoff
Parkview	6/19/19	Report of Leak
Johnson Trail	6/20/19	Report of Leak
Parcel B	6/21/19	High Float Alarm
Parcel B	6/23/19	Level Adjustment
Elm Tank	6/29/19	Low Level
Office Telemetry	6/29/19	Reset Computer

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**