

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of May 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 852,900 Cubic Ft.

Water sold: 742,700 Cubic Ft.

Water used for Fire & Flushing Line: 59,703 Cubic Ft.

Lag Differential: 5.92%

Average chlorine residual: 0.65 MG/L

II. MAINTENANCE AND REPAIR: May 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	1	5
AFTER HOUR CALL OUTS	4	1	23
MAIN LINE LEAK REPAIRS	2	6	23
USA LOCATES	34	32	112
SERVICE/WORK ORDERS	157	187	759
CUSTOMER "TURN-ONS"	3	5	19
CUSTOMER "TURN-OFFS"	2	5	13
LOCK OFF (NON PAYMENT)	4	11	42
SERVICE RECONNECT	4	4	24
SHUT OFF NOTICES	51	52	243
GALLONS CL2 USED	95	91	456
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of May 2017

Location	Dates	Comments
Corp Yard	5/04/17	4" Mainline
Corp Yard	5/04/17	4" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (4) after hour callout(s) in the month of May 2017

Location	Dates	Comments
3741 Los Padres	5/20/17	Emergency Shutoff
4132 Elliot	5/20/17	Fire Hydrant Leak
System Alarm	5/20/17	Pine 2 Failure
System Alarm	5/27/17	Elm Tank Power Failure

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE –**