

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of December 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,015,300 Cubic Ft.

Water sold: 752,100 Cubic Ft.

Water used for Fire & Flushing Line: 71,071 Cubic Ft.

Lag Differential: 18.92%

Average chlorine residual: 0.77 MG/L

II. MAINTENANCE AND REPAIR: December 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	2	19
AFTER HOUR CALL OUTS	1	2	35
MAIN LINE LEAK REPAIRS	1	2	33
USA LOCATES	9	3	205
SERVICE/WORK ORDERS	140	128	1814
CUSTOMER "TURN-ONS"	0	0	27
CUSTOMER "TURN-OFFS"	1	0	26
LOCK OFF (NON PAYMENT)	9	10	112
SERVICE RECONNECT	9	6	80
SHUT OFF NOTICES	31	45	519
GALLONS CL2 USED	90	94	1018
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of December 2017

Location	Dates	Comments
East End Drive	12/26/17	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (1) after hour callout(s) in the month of December 2017

Location	Dates	Comments
728 Santa Rosa	12/22/17	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**