

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of April 2018

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 840,600 Cubic Ft.

Water sold: 635,400 Cubic Ft.

Water used for Fire & Flushing Line: 58,842 Cubic Ft.

Lag Differential: 17.41%

Average chlorine residual: 0.53 MG/L

II. MAINTENANCE AND REPAIR: April 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	1	3
AFTER HOUR CALL OUTS	0	1	10
MAIN LINE LEAK REPAIRS	2	1	4
USA LOCATES	7	16	36
SERVICE/WORK ORDERS	142	217	664
CUSTOMER "TURN-ONS"	0	2	2
CUSTOMER "TURN-OFFS"	0	2	5
LOCK OFF (NON PAYMENT)	10	8	33
SERVICE RECONNECT	9	5	30
SHUT OFF NOTICES	32	38	121
GALLONS CL2 USED	89	94	359
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of April 2018

Location	Dates	Comments
Santa Rosa/Los Padres	4/11/18	4" Mainline
Los Padres	4/16/18	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (0) after hour callout(s) in the month of April 2018

Location	Dates	Comments

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**