

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of December 2018

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 798,100 Cubic Ft.

Water sold: 651,342 Cubic Ft. After Correction

Water used for Fire & Flushing Line: 55,867 Cubic Ft.

Lag Differential: 11.39%

Average chlorine residual: 1.09 MG/L

II. MAINTENANCE AND REPAIR: December 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	6	18
AFTER HOUR CALL OUTS	3	0	26
MAIN LINE LEAK REPAIRS	4	1	23
USA LOCATES	3	14	131
SERVICE/WORK ORDERS	76	195	1832
CUSTOMER "TURN-ONS"	0	0	11
CUSTOMER "TURN-OFFS"	0	0	14
LOCK OFF (NON PAYMENT)	7	4	98
SERVICE RECONNECT	4	9	76
SHUT OFF NOTICES	27	23	350
GALLONS CL2 USED	153	139	1419
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (4) mainline break(s) / repair(s) in the month of December 2018

Location	Dates	Comments
Los Padres/San Gabriel	12/08/18	8" Mainline
3804 Johnson	12/09/18	4" Mainline
4312 Logan/Grant	12/12/18	2" Mainline
801 Buena Vista	12/17/18	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (3) after hour callout(s) in the month of December 2018

Location	Dates	Comments
720 Pasadena	12/22/18	Emergency Shutoff
8718 Walnut	12/30/18	Emergency Shutoff
3708 Kiwanis	12/31/18	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**