

***FRAZIER PARK PUBLIC UTILITY  
DISTRICT***

**MANAGERS REPORT**

**For the month of March 2020**

**Prepared by:**

**Jonnie Allison, General Manager**

**Frazier Park Public Utility District**

## INFORMATIONAL ITEMS

### I. WATER REPORT

**Water Pumped this month 848,800 Cubic Ft.**

**Water sold: 672,025 Cubic Ft.**

**Water used for Fire & Flushing Line: 59,416 Cubic Ft.**

**Lag Differential: 13.83%**

**Water Loss: 117,359 Cubic Feet**

**Average chlorine residual: 0.99 MG/L**

### II. MAINTENANCE AND REPAIR: March 2020

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	1	3
AFTER HOUR CALL OUTS	1	5	14
MAIN LINE LEAK REPAIRS	4	0	5
USA LOCATES	6	1	15
SERVICE/WORK ORDERS	87	202	506
CUSTOMER "TURN-ONS"	1	2	5
CUSTOMER "TURN-OFFS"	1	4	7
LOCK OFF (NON PAYMENT)	0	5	16
SERVICE RECONNECT	2	14	19
SHUT OFF NOTICES	0	27	62
GALLONS CL2 USED	146	147	437
WATER QUALITY COMPLAINTS	0	0	0

### III. WATER QUALITY COMPLAINTS:

**IV. ISSUES AND ACTIONS:**

There was (4) mainline break(s) / repair(s) in the month of March 2020

Location	Dates	Comments
4405 Hale Trail/Mead	3/05/20	6" Mainline
132 Logan/Grant	3/11/20	2" Mainline
901 Piedmont/San Carlos	3/13/20	6" Mainline (C900) Connection to 4" Steel Broken Valve
Mt. Pinos & Birch Trail	3/17/20	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of March 2020

Location	Dates	Comments
Magee Tank	3/08/20	System Alarm

**V. NEW SERVICES INSTALLED: (0)**

Address		Lot / Block / Tract	Size

**VI. NEW BUSINESS:**

- **APPLICATIONS FOR WATER SERVICE - 0**