

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of December 2016

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 6,601,000 Gallons

Water sold: 5,058,100 Gallons

Lag Differential: 16.37%

Average chlorine residual: 0.80 MG/L

II. MAINTENANCE AND REPAIR: December 2016

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	3	0	35
AFTER HOUR CALL OUTS	10	3	141
MAIN LINE LEAK REPAIRS	2	1	19
USA LOCATES	18	27	221
SERVICE/WORK ORDERS	102	140	1349
CUSTOMER "TURN-ONS"	3	1	46
CUSTOMER "TURN-OFFS"	3	1	33
LOCK OFF (NON PAYMENT)	3	10	80
SERVICE RECONNECT	7	6	52
SHUT OFF NOTICES	33	49	434
GALLONS CL2 USED	99	89	1296
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of December 2016

Location	Dates	Comments
East End & Nebraska	12/26/16	¾" Mainline
East End & Nebraska	12/28/16	¾" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (10) after hour callout(s) in the month of December 2016

Location	Dates	Comments
2105 Roosevelt	12/20/16	Emergency Shutoff
3105 Harriet	12/20/16	Emergency Shutoff
System Alarm	12/22/16	Power Failure
Entire System	12/23/16	Run Wells by Hand
Entire System	12/24/16	Startup System after Power Rest.
East End & Nebraska	12/26/16	¾" Mainline Leak
East End & Nebraska	12/28/16	¾" Mainline Leak
System Alarm	12/28/16	Reset Scada
System Alarm	12/30/16	Communication Failure
System Alarm	12/31/16	Communication Failure

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

■ **APPLICATIONS FOR WATER SERVICE -**