

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of August 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,620,000 Cubic Ft.

Water sold: 2,086,690 Cubic Ft.

Water used for Fire & Flushing Line: 113,400 Cubic Ft.

Lag Differential: -35.81% Not accurate. Well 6 Meter in-op

Average chlorine residual: 1.04 MG/L

II. MAINTENANCE AND REPAIR: August 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	2	0	5
AFTER HOUR CALL OUTS	0	12	43
MAIN LINE LEAK REPAIRS	4	2	20
USA LOCATES	5	16	97
SERVICE/WORK ORDERS	175	193	1439
CUSTOMER "TURN-ONS"	3	4	18
CUSTOMER "TURN-OFFS"	4	1	15
LOCK OFF (NON PAYMENT)	6	7	43
SERVICE RECONNECT	6	7	42
SHUT OFF NOTICES	29	26	258
GALLONS CL2 USED	166	155	1041
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (4) mainline break(s) / repair(s) in the month of August 2019

Location	Dates	Comments
633 Alhambra & Mt. Pinos	8/01/19	2" Mainline
4337 Hale Trail	8/05/19	¾" Mainline
Los Padres & Alhambra	8/22/19	2" Mainline
Feeder line on hillside	8/30/19	8" Mainline from Elm to Forestry

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (0) after hour callout(s) in the month of August 2019

Location	Dates	Comments

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**

