

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of September 2018

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,331,400 Cubic Ft.

Water sold: 1,080,800 Cubic Ft.

Water used for Fire & Flushing Line: 93,198 Cubic Ft.

Lag Differential: 11.82%

Average chlorine residual: 0.56 MG/L

II. MAINTENANCE AND REPAIR: September 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	0	5
AFTER HOUR CALL OUTS	1	6	21
MAIN LINE LEAK REPAIRS	4	2	14
USA LOCATES	6	26	101
SERVICE/WORK ORDERS	160	124	1373
CUSTOMER "TURN-ONS"	1	1	9
CUSTOMER "TURN-OFFS"	2	2	12
LOCK OFF (NON PAYMENT)	4	10	76
SERVICE RECONNECT	6	6	57
SHUT OFF NOTICES	25	36	265
GALLONS CL2 USED	154	149	970
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (4) mainline break(s) / repair(s) in the month of September 2018

Location	Dates	Comments
East End (at S Curves)	9/04/18	2" Mainline
4120 Summit	9/11/18	4" Mainline
Los Padres (Between Escolon & Buena Vista)	9/13/18	2" Mainline
Elm Trail	9/27/18	8" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of September 2018

Location	Dates	Comments
3113 Locust	9/14/18	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**