

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of December 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 874,100 Cubic Ft.

Water sold: 517,660 Cubic Ft.

Water used for Fire & Flushing Line: 61,187 Cubic Ft.

Lag Differential: 33.78%

Average chlorine residual: 1.22 MG/L

II. MAINTENANCE AND REPAIR: December 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	0	10
AFTER HOUR CALL OUTS	3	5	51
MAIN LINE LEAK REPAIRS	1	0	25
USA LOCATES	1	6	130
SERVICE/WORK ORDERS	176	145	2091
CUSTOMER "TURN-ONS"	1	1	22
CUSTOMER "TURN-OFFS"	1	1	19
LOCK OFF (NON PAYMENT)	6	5	68
SERVICE RECONNECT	5	4	64
SHUT OFF NOTICES	22	37	373
GALLONS CL2 USED	150	148	1656
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of December 2019

Location	Dates	Comments
336 Arizona	12/05/2019	6" Steel Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (3) after hour callout(s) in the month of December 2019

Location	Dates	Comments
Elm Tank Booster	12/18/19	System Alarm
4333 Alcot	12/21/19	Activation after Emergency Shutoff
4340 Alcot	12/29/19	Emergency Shut off

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**

