

***FRAZIER PARK PUBLIC UTILITY  
DISTRICT***

**MANAGERS REPORT**

**For the month of June 2018**

**Prepared by:**

**Jonnie Allison, General Manager**

**Frazier Park Public Utility District**

## INFORMATIONAL ITEMS

### I. WATER REPORT

**Water Pumped this month 1,246,800 Cubic Ft.**

**Water sold: 1,028,200 Cubic Ft.**

**Water used for Fire & Flushing Line: 87,276 Cubic Ft.**

**Lag Differential: 10.53%**

**Average chlorine residual: 0.51 MG/L**

### II. MAINTENANCE AND REPAIR: June 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	1	4
AFTER HOUR CALL OUTS	1	0	11
MAIN LINE LEAK REPAIRS	2	0	6
USA LOCATES	20	3	59
SERVICE/WORK ORDERS	144	140	948
CUSTOMER "TURN-ONS"	0	3	5
CUSTOMER "TURN-OFFS"	0	2	7
LOCK OFF (NON PAYMENT)	9	6	48
SERVICE RECONNECT	3	7	40
SHUT OFF NOTICES	29	26	176
GALLONS CL2 USED	92	93	544
WATER QUALITY COMPLAINTS	0	0	0

### III. WATER QUALITY COMPLAINTS:

**IV. ISSUES AND ACTIONS:**

There was (2) mainline break(s) / repair(s) in the month of June 2018

Location	Dates	Comments
Logan Trail	6/10/18	4" Mainline
Buena Vista	6/17/18	8" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of June 2018

Location	Dates	Comments
Downtown Project	6/17/18	Leak on Sprinkler Sytem

**V. NEW SERVICES INSTALLED: (0)**

Address		Lot / Block / Tract	Size

**VI. NEW BUSINESS:**

- **APPLICATIONS FOR WATER SERVICE -**