

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of November 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 971,400 Cubic Ft.

Water sold: 762,000 Cubic Ft.

Water used for Fire & Flushing Line: 67,998 Cubic Ft.

Lag Differential: 14.56%

Average chlorine residual: 0.61 MG/L

II. MAINTENANCE AND REPAIR: November 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	2	4	19
AFTER HOUR CALL OUTS	2	2	34
MAIN LINE LEAK REPAIRS	2	1	32
USA LOCATES	3	12	196
SERVICE/WORK ORDERS	128	185	1674
CUSTOMER "TURN-ONS"	0	3	27
CUSTOMER "TURN-OFFS"	0	2	25
LOCK OFF (NON PAYMENT)	10	16	103
SERVICE RECONNECT	6	12	71
SHUT OFF NOTICES	45	50	488
GALLONS CL2 USED	94	92	928
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of November 2017

Location	Dates	Comments
Behind Lions Daycare	11/23/17	Tree Busted 4" ACP Pipe
District Maint. Yard	11/20/17	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (2) after hour callout(s) in the month of November 2017

Location	Dates	Comments
4144 Truman	11/05/17	Emergency Shutoff House Fire
Lions Daycare	11/24/17	Tree Busted 4" ACP Pipe

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**