

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of June 2021

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,554,800 Cubic Ft.

Water sold: 899,960 Cubic Ft.

Water used for Fire & Flushing Line: 108,836 Cubic Ft.

Lag Differential: 35.12%

Water Loss: 546,004 Cubic Feet

Average chlorine residual: 1.21 MG/L

II. MAINTENANCE AND REPAIR: June 2021

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	5	3	13
AFTER HOUR CALL OUTS	11	10	70
MAIN LINE LEAK REPAIRS	2	2	13
USA LOCATES	4	2	92
SERVICE/WORK ORDERS	211	183	976
CUSTOMER "TURN-ONS"	1	0	3
CUSTOMER "TURN-OFFS"	1	0	7
LOCK OFF (NON PAYMENT)	0	0	0
SERVICE RECONNECT	1	1	2
SHUT OFF NOTICES	0	0	0
GALLONS CL2 USED	150	149	895
WATER QUALITY COMPLAINTS	1	0	1

III. WATER QUALITY COMPLAINTS: Unfounded Report.

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of June 2021

Location	Dates	Comments
Los Padres & Santa Cruz	6/8/21	2- 4" Clamps
Escolon & I Ave	6/22/21	1- 1" Clamp

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (10) after hour callout(s) in the month of June 2021

Location	Dates	Comments
Elm Booster	6/16/21	Booster # 2 System Alarm
Elm Booster	6/16/21	Booster # 2 System Alarm
Parcel B Valve	6/18/21	Closed Parcel B Fill Valve
3550 Ohio Trail	6/18/21	Water Running
Magee Tank	6/19/21	Low Tank Level
Magee Tank	6/20/21	Low Tank Level
Sam Young Tank	6/20/21	Low Tank Alarm
Elm, Wolfe, Harrison, Pine 1	6/20/21	Manually Operating Boosters
Harrison, Elm Tanks	6/20/21	Manually Operating Boosters
Forestry Tank	6/22/21	High Tank Alarm
848 Escolon Trail	6/22/21	1" Line Failure

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**