

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of March 2023

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,325,000 Cubic Ft.

Water sold: 604,680 Cubic Ft.

Water used for Fire & Flushing Line: 92,750 Cubic Ft.

Lag Differential: 47.36%

Average chlorine residual: 0.75 MG/L

II. MAINTENANCE AND REPAIR: March 2023

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	3	1	7
AFTER HOUR CALL OUTS	6	8	19
MAIN LINE LEAK REPAIRS	3	1	6
USA LOCATES	23	7	46
SERVICE/WORK ORDERS	474	237	999
CUSTOMER "TURN-ONS"	1	0	1
CUSTOMER "TURN-OFFS"	0	1	1
LOCK OFF (NON PAYMENT)	2	1	9
SERVICE RECONNECT	5	2	10
SHUT OFF NOTICES	38	34	118
GALLONS CL2 USED	149	119	404
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	1	0	1
SERVICE LINE BREAKS	0	0	1
BOIL WATER NOTICES	175	0	175

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (3) mainline break(s) / repair(s) in the month of March 2023

Location	Dates	Comments
San Miguel & Mt. Pinos	3/7/23	4" Steel
34.8199522-118.9413561	3/8/23	6" White PVC
624 Julin Trail	3/16/23	4" Steel

- Eight (8) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and four (4) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (6) after hour callout(s) in the month of March 2023

Location:	Date:	Reason:
Well 5	3/6/23	Well 5 Low Float
Well 5	3/7/23	Well 5 Low Float
Well 5 Booster Station	3/8/23	Booster Pump #1 Failure
857 Walnut	3/12/23	Emergency Shut Off
Corporate Yard	3/19/23	Alarm Response. Nothing Found
Corporate Yard	3/24/23	Alarm Response. Nothing Found

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE – 0**