

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of May 2018

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,016,300 Cubic Ft.

Water sold: 814,600 Cubic Ft.

Water used for Fire & Flushing Line: 71,141 Cubic Ft.

Lag Differential: 12.85%

Average chlorine residual: 0.38 MG/L

II. MAINTENANCE AND REPAIR: May 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	1	4
AFTER HOUR CALL OUTS	0	0	10
MAIN LINE LEAK REPAIRS	0	2	4
USA LOCATES	3	7	39
SERVICE/WORK ORDERS	140	142	804
CUSTOMER "TURN-ONS"	3	0	5
CUSTOMER "TURN-OFFS"	2	0	7
LOCK OFF (NON PAYMENT)	6	10	39
SERVICE RECONNECT	7	9	37
SHUT OFF NOTICES	26	32	147
GALLONS CL2 USED	93	89	452
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (0) mainline break(s) / repair(s) in the month of May 2018

Location	Dates	Comments

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (0) after hour callout(s) in the month of May 2018

Location	Dates	Comments

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**