FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGERS REPORT

For the month of May 2023

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,175,700 Cubic Ft.

Water sold: 669,050 Cubic Ft.

Water used for Fire & Flushing Line: 82,299 Cubic Ft.

Lag Differential: 36.09%

Average chlorine residual: 0.85 MG/L

II. MAINTENANCE AND REPAIR: May 2023

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	6	8	21
AFTER HOUR CALL OUTS	2	3	24
MAIN LINE LEAK REPAIRS	6	5	17
USA LOCATES	21	38	105
SERVICE/WORK ORDERS	318	464	1781
CUSTOMER "TURN-ONS"	1	1	3
CUSTOMER "TURN-OFFS"	0	0	3
LOCK OFF (NON PAYMENT)	7	3	19
SERVICE RECONNECT	7	4	21
SHUT OFF NOTICES	37	41	196
GALLONS CL2 USED	143	135	682
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	1	0	1
SERVICE LINE BREAKS	1	0	2
BOIL WATER NOTICES	40	150	365

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (6) mainline break(s) / repair(s) in the month of May 2023

	- (- <i>)</i> / - I (-	
Location	Dates	Comments
4332 Irvon/Mead	05/02/23	2" Steel
California & East End	05/02/23	4" Steel
Summit Trail	05/03/23	4" Steel
2900 Johnson Road	05/19/23	4" Steel
3125 Harriet Road	05/21/23	6" PVC
4337 Irvon Trail	05/29/23	2" Steel

- Eight (8) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and four (4) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (2) after hour callout(s) in the month of May 2023

Location: Date: Reason:

Docation.	Batt.	110000111
Harrison Tank	05/08/23	Booster Pump Failure
Monterey Trail	05/12/23	Leak Reported. Determined to be a meter box

V. <u>NEW SERVICES INSTALLED:</u> (0)

Address	Lot / Block / Tract	Size

VI. NEW BUSINESS:

■ APPLICATIONS FOR WATER SERVICE - 0