

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of March 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 942,800 Cubic Ft.

Water sold: 597,689 Cubic Ft. After Correction

Water used for Fire & Flushing Line: 65,996 Cubic Ft.

Lag Differential: 29.61%

Average chlorine residual: 1.12 MG/L

II. MAINTENANCE AND REPAIR: March 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	0	1
AFTER HOUR CALL OUTS	4	7	20
MAIN LINE LEAK REPAIRS	2	2	7
USA LOCATES	4	13	22
SERVICE/WORK ORDERS	209	101	486
CUSTOMER "TURN-ONS"	2	3	7
CUSTOMER "TURN-OFFS"	2	3	5
LOCK OFF (NON PAYMENT)	4	4	13
SERVICE RECONNECT	3	4	13
SHUT OFF NOTICES	30	31	110
GALLONS CL2 USED	112	112	356
WATER QUALITY COMPLAINTS	0	0	

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of March 2019

Location	Dates	Comments
East End & Michigan	3/16/19	2" Main
Logan Tr. & Grant	3/13/19	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (7) after hour callout(s) in the month of March 2019

Location	Dates	Comments
936 Elm Trail	3/2/19	Emergency Shut Off
4159 Pico Trail	3/2/19	Emergency Shut Off
4159 Pico Trail	3/3/19	Emergency Shut Off/Steel Lock
3408 Mt. Pinos	3/11/19	Emergency Shut Off

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**