

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of August 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 954,000 Cubic Ft.

Water sold: 804,200 Cubic Ft.

Water used for Fire & Flushing Line: 66,780 Cubic Ft.

Lag Differential: 8.70%

Average chlorine residual: 0.59 MG/L

II. MAINTENANCE AND REPAIR: August 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	6	12
AFTER HOUR CALL OUTS	2	3	29
MAIN LINE LEAK REPAIRS	2	3	29
USA LOCATES	17	15	166
SERVICE/WORK ORDERS	168	143	1221
CUSTOMER "TURN-ONS"	1	3	23
CUSTOMER "TURN-OFFS"	2	2	21
LOCK OFF (NON PAYMENT)	12	8	73
SERVICE RECONNECT	8	3	42
SHUT OFF NOTICES	52	37	349
GALLONS CL2 USED	99	95	742
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of August 2017

Location	Dates	Comments
Summit	8/23/17	4" Mainline Rupture
Mead Trail	8/24/17	6" Mainline Repair

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (2) after hour callout(s) in the month of August 2017

Location	Dates	Comments
System Alarm	8/18/17	Unknown Alarm
System Alarm	8/24/17	Unknown Alarm

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**