

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of July 2018

Prepared by:

**Jonnie Allison, General Manager
Frazier Park Public Utility District**

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,260,300 Cubic Ft.

Water sold: 1,065,100 Cubic Ft.

Water used for Fire & Flushing Line: 88,221 Cubic Ft.

Lag Differential: 8.49%

Average chlorine residual: 0.95 MG/L

II. MAINTENANCE AND REPAIR: July 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	1	4
AFTER HOUR CALL OUTS	3	1	14
MAIN LINE LEAK REPAIRS	2	0	8
USA LOCATES	10	20	69
SERVICE/WORK ORDERS	141	144	1089
CUSTOMER "TURN-ONS"	2	0	7
CUSTOMER "TURN-OFFS"	1	0	8
LOCK OFF (NON PAYMENT)	14	9	62
SERVICE RECONNECT	5	3	45
SHUT OFF NOTICES	28	29	204
GALLONS CL2 USED	123	92	667
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of July 2018

Location	Dates	Comments
East End & Minnesota	7/10/2018	2" Mainline
Manita Trail	7/03/2018	3" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (3) after hour callout(s) in the month of July 2018

Location	Dates	Comments
4132 Spruce	7/7/2018	Emergency Shutoff
3537 Mt. Pinos	7/7/2018	Emergency Shutoff
Pomona Trail (Church)	7/20/2018	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**