

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of February 2020

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 918,600 Cubic Ft.

Water sold: 691,025 Cubic Ft.

Water used for Fire & Flushing Line: 64,302 Cubic Ft.

Lag Differential: 17.77%

Water Loss: 163,273 Cubic Feet

Average chlorine residual: 1.04 MG/L

II. MAINTENANCE AND REPAIR: February 2020

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	1	2
AFTER HOUR CALL OUTS	5	8	13
MAIN LINE LEAK REPAIRS	0	1	1
USA LOCATES	1	8	9
SERVICE/WORK ORDERS	202	217	419
CUSTOMER "TURN-ONS"	2	2	4
CUSTOMER "TURN-OFFS"	4	1	6
LOCK OFF (NON PAYMENT)	5	11	16
SERVICE RECONNECT	4	13	17
SHUT OFF NOTICES	27	35	62
GALLONS CL2 USED	147	144	291
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (0) mainline break(s) / repair(s) in the month of February 2020

Location	Dates	Comments

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (5) after hour callout(s) in the month of February 2020

Location	Dates	Comments
Well 6	2/18/20	System Alarm
Pine 2	2/19/20	System Alarm
3825 Arroyo	2/29/20	Emergency Shutoff
3509 Nebraska	2/29/20	Emergency Shutoff
4046 Pico	2/29/20	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**