

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of July 2020

Prepared by:

**Jonnie Allison, General Manager
Frazier Park Public Utility District**

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,426,800 Cubic Ft.

Water sold: 1,495,227 Cubic Ft.

Water used for Fire & Flushing Line: 99,876 Cubic Ft.

Lag Differential: -11.80%

Water Loss: 168,303 Cubic Feet

Average chlorine residual: .70 MG/L

II. MAINTENANCE AND REPAIR: July 2020

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	3	1	7
AFTER HOUR CALL OUTS	2	3	39
MAIN LINE LEAK REPAIRS	0	5	20
USA LOCATES	59	15	104
SERVICE/WORK ORDERS	218	174	1586
CUSTOMER "TURN-ONS"	4	3	15
CUSTOMER "TURN-OFFS"	1	1	12
LOCK OFF (NON PAYMENT)	1	0	17
SERVICE RECONNECT	0	0	19
SHUT OFF NOTICES	0	0	62
GALLONS CL2 USED	149	154	1030
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (0) mainline break(s) / repair(s) in the month of July 2020

Location	Dates	Comments

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (2) after hour callout(s) in the month of July 2020

Location	Dates	Comments
Wolfe Tank	7/18/20	Tank Spigot Damaged
Office	7/18/20	District Yard Alarm

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**