

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of April 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 740,500 Cubic Ft.

Water sold: 637,700 Cubic Ft.

Water used for Fire & Flushing Line: 51,835 Cubic Ft.

Lag Differential: 6.88%

Average chlorine residual: 0.85 MG/L

II. MAINTENANCE AND REPAIR: April 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	3	4
AFTER HOUR CALL OUTS	1	5	19
MAIN LINE LEAK REPAIRS	6	3	21
USA LOCATES	32	19	78
SERVICE/WORK ORDERS	187	155	602
CUSTOMER "TURN-ONS"	5	5	16
CUSTOMER "TURN-OFFS"	5	3	11
LOCK OFF (NON PAYMENT)	11	11	38
SERVICE RECONNECT	4	9	20
SHUT OFF NOTICES	52	56	192
GALLONS CL2 USED	91	90	361
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (6) mainline break(s) / repair(s) in the month of April 2017

Location	Dates	Comments
920 Elm Trail	4/06/17	8" Mainline
Manita Trail	4/12/17	4" Mainline
Manita Trail	4/12/17	4" Mainline
Manita Trail	4/12/17	4" Mainline
Manita Trail	4/12/17	4" Mainline
Elm Trail	4/17/17	8" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of April 2017

Location	Dates	Comments
East End & Nebraska Trail	4/05/17	Water Running Down Street/Garden Hose

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**