FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGERS REPORT

For the month of October 2016

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 9,189,000 Gallons

Water sold: 7,329,400 Gallons
Lag Differential: 13.24%
Average chlorine residual: 0.63 MG/L

II. MAINTENANCE AND REPAIR: October 2016

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	7	8	32
AFTER HOUR CALL OUTS	3	8	128
MAIN LINE LEAK REPAIRS	3	1	14
USA LOCATES	0	5	176
SERVICE/WORK ORDERS	125	168	1107
CUSTOMER "TURN-ONS"	3	1	40
CUSTOMER "TURN-OFFS"	2	1	29
LOCK OFF (NON PAYMENT)	5	10	67
SERVICE RECONNECT	5	10	39
SHUT OFF NOTICES	34	38	352
GALLONS CL2 USED	101	66	1108
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (3) mainline break(s) / repair(s) in the month of October 2016

Location	Dates	Comments
Behind Fire station	10/08/16	4" Magee Main
Parcel "B"	10/04/16	8" Parcel "B" Main
3642 Main Trail	10/25/16	1" Main

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (3) after hour callout(s) in the month of October 2016

Location	Dates	Comments
System Alarm	10/07/16	Unknown System Alarm
Customer C/O	10/07/16	Customer Leak
Behind Fire Station	10/08/16	8" Mainline to Magee Tank

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE –**